

TYPE APPROVAL CERTIFICATE

CERTIFICATE No. : 25-IS-0980-TAT-25-COC-0294

Name of Manufacturer : ÇAYIROVA BORU SANAYI VE TICARET A.Ş

Address : Osmangazi Mah. Aşıroğlu Cad. No:170 Darıca/Kocaeli / Türkiye

Object : Manufacturing of Non alloy steel tubes for the conveyance of water and aqueous liquids EN 10224 Table1 Carbon steel materials; L235 & L275 & L355

Outside diameter: 26.9 to 323.9 mm

Wall Thickness: 1.8 mm to 12 mm

Type : Non alloy steel tubes EN 10224 Table1 Carbon steel materials; L235 & L275 & L355

Test basis according : EN 10224:2002 & 305/2011 Construction Products Directive

Test report No : See 22-IS-0821 Technical file which includes related test reports

Test Pressure : Acc. To EN 10224 Part 10.3.2

Pipe Materials : EN 10224 Table1 Carbon steel materials; L235 & L275 & L355

Max/Min Working temp : Room Temperature

Dimension : EN 10224:2002 Part 7.6 Table 4 : Tube outside diameter and thickness

We here with certify that the results of the examination of the Non alloy steel tubes for the conveyance of water and aqueous liquids EN 10224 Table1 Carbon steel materials ;L235 & L275 & L355 mentioned above meet the requirement of the EN 10224 & 305/2011 Construction Products Directive.

This approval remains valid as long as no significant changes are made to the production line and its quality system and batch test certificates.

Date of issue: 09.06.2025



Signature:
TÜV AUSTRIA
Hakim ÖZLÜK