



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Non-Threadable Lightwall Sprinkler Pipe

Model Direct-Flow

1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4 and 6 inch NPS

For Use with Victaulic Company's Style 009N Rigid and Style 75 Flexible Grooved Couplings

Prepared for:

Cayirova Boru San ve Tic AS
Osmangazi Mah. Aşıroğlu Cad. No: 170
Darıca/ KOCAELİ, 41700
Turkey

Manufactured at:

Cayirova Boru San ve Tic AS
Osmangazi Mah. Aşıroğlu Cad. No: 170
Darıca/ KOCAELİ, 41700
Turkey

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”, June 2021

Approval Identification: PR458223

Approval Granted: 27 March 2025

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller
VP - Manager of Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062

