

CERTIFICATE OF COMPLIANCE

Certificate Number EX27808
Report Reference EX27808-20230427
Date 2023-May-01

Issued to: CAYIROVA BORU SAN VE TIC A S
Osmangazi Mahallesi Asiroglu Caddesi, No 170
Darica-Kocaeli 41700 TR

This is to certify that representative samples of METALLIC SPRINKLER PIPE
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX27808
Report Reference EX27808-20230427
Date 2023-May-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Metallic Sprinkler Pipe

Model EN 10255 Medium steel sprinkler pipe, 1 in. through 6-1/2 OD sizes nominal diameter for wet, dry preaction and deluge-type sprinkler systems with unthreaded ends intended to be joined by welding or by Listed rubber-gasketed fittings as indicated in the individual Listings under the category for Fittings, Rubber Gasketed (VIZM) when installed in accordance with the fitting manufacturer's specifications where rated pressure and corrosion resistance ratios (CRR) are as follows:

Pipe Size (in.)	Outside Diameter, mm	Wall Thickness, mm	Rated Pressure psig	CRR Unthreaded
1	33.7	3.2	300	15.73
1-1/4	42.4	3.2	300	10.10
1-1/2	48.3	3.2	300	8.05
3 OD	76.1	3.6	300	5.33
5-1/2 OD	139.7	5.0	300	4.31
6-1/2 OD	165.1	5.0	300	2.97

Model Direct Flow steel sprinkler pipe, 1 in. through 3 in. sizes nominal diameter for wet, dry preaction and deluge-type sprinkler systems with unthreaded ends intended to be joined by welding or by Listed rubber-gasketed fittings as indicated in the individual Listings under the category for Fittings, Rubber Gasketed (VIZM) when installed in accordance with the fitting manufacturer's specifications where rated pressure and corrosion resistance ratios (CRR) are as follows:

Pipe Size (in.)	Outside Diameter, mm	Wall Thickness, mm	Rated Pressure psig	CRR Unthreaded
1	33.4	2.00	300	3.84
1-1/4	42.2	2.00	300	2.47
1-1/2	48.3	2.13	300	2.36
2-1/2	73.0	2.18	300	1.19
3	88.9	2.36	300	1.10

Deborah Jennings-Conner
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>