

CERTIFICATE OF COMPLIANCE

Certificate Number 20180531-EX27808
Report Reference EX27808-20180530
Issue Date 2018-MAY-31

Issued to: CAYIROVA BORU SAN VE TIC A S
Osmangazi Mahallesi Asiroglu Caddesi No 170
Darica-Kocaeli TURKEY

**This is to certify that
representative samples of**

METALLIC SPRINKLER PIPE
Schedule 10 (black or galvanized) steel pipe in the 3/4, 1, 1-
1/4, 1-1/2, 2, 2-1/2, 3, 4, 6, 8, and 10 inch sizes.

Schedule 30 steel pipe in the 8 and 10 inch sizes.

Schedule 40 (black or galvanized) steel pipe in the 1/2, 3/4,
1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10 inch sizes.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe For Fire Protection
ULC/ORD C199S, Light Wall Steel Pipes for Sprinkler
Systems for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

